



Kankarwal & Associates

Mob. No. 82953-59597

98962-19796

Architects, Engineers, Valuers, Estimators & Land Survey Consultants

indri Chowk, **Ladwa** (Kurukshetra)

Email: ravidutt577@gmail.com

Ref. No. HOBPAS-REG-88/18-19

Dated 19-09-2024

Annexure-D

BUILDING SAFETY CERTIFICATE

No.

Dated 19-09-2024

It is certified that the existing building & (name of the building or premises at **SANJAY GRANDHI OM PARKASH GARG**

MEMORIAL PUBLIC SCHOOL SUJRA (address) is having block(s) floor(s) as per details below: **BABAIN**

Detail of Block (s) in School	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s)	Ground First Second 3					

The building is owned/occupied by **Sanjay Gandhi Om parkash garg**
Memorial Public School Sujra Babain (Name of the institution) have complied with the Building Safety requirements in accordance with National Building code Rules, and verified by the officials concerned of (date of inspection) in the presence of **Mr. Ravinder Bansal** (Name and address of the Manager/Secretary or his representative) and that the building /premises is fit for occupancy for running school with effect from **19/9/2024** for a period of **1** years in accordance with rule and subject to compliance of the specific condition as appended.

Issued on at by

ER. SUMIT KUMAR

M.tech STRUCTURE
HOBPAS-REG-88/18-19
Ph: 82953-59597

Signature with seal;

Name **ER. SUMIT KUMAR**

Designation **B'tech, M'tech civil**

Name & Address of Office **BDO OFFICE ROAD**
Ambedkar Chowk
Ladwa.



Kankarwal & Associates

Mob. No. 82953-59597
98962-19796

Architects, Engineers, Valuers, Estimators & Land Survey Consultants

Indri Chowk, Ladwa (Kurukshetra)

Email: ravidutt577@gmail.com

LIC NO. HOBPAS-REG-88/18-19

Ref. No. HOBPAS-REG-88/18-19

Dated. 12-09-2024

CERTIFICATE FOR STRUCTURAL SUITABILITY

CERTIFICATE to be submitted along with the building application only signed by a qualified Engineer Certified that the structural parts of the entire building situated at Village Sujra, Babain Sub. Tehsil Babain Distt. Kurukshetra Street/Road belonging to Sanjay Gandhi Om Parkash Garg Memorial Public School Sujra (Babain) Distt. Kurukshetra have been designed by me on basis of calculation and are considered safe in accordance with permissible stresses and slenderness ratios as laid down in the bye-laws.

The specifications are as below:-

<u>ITEMS</u>	<u>SPECIFICATIONS</u>
1. Foundations	C.Conc. 1:8:16
2. Walls	First Class brick work laid in cement sand mortar (1:7)
3. Damp. Proof Course (DPC)	40 mm th. C.Conc. 1:2:4 with two coats of hot bitumens laid.
4. Roof	115 mm th. R.C.C slab (1:2:4) as per I.S. 456 with two coats hot bitumens laid.
5. Steel work	Cold twisted mild steel deformed bars as per I.S. 229.
6. Floors	There is C.conc. flooring in the rooms and verandah.
7. Doors, Windows and other	Chowkets of Z-Section/M.S. angle iron and shutters of the wood works doors & windows paneled and enamel painted
8. Internal Finish	cement plastering with cement mortar (1:5) finished with two coats of white wash.
9. External Finish	cement plastering with cement mortar (1:5) finished with two coats of white wash.
10. Ventilation	Full size windows have been provided along with doors and are sufficient for ventilation.

Signature of the Engineer.

ER. SUMIT KUMAR 12/9/2024
HOBPAS-REG-88/18-19
KANKARWAL & ASSOCIATES
Architects, Engineers, Valuers
800 Office, Road, Ladwa (KKR)